



NOTE:

1. Service shall be a minimum of 10' deep at the right of way or easement line unless otherwise approved by the City Engineer.
2. Provide 5 lb magnesium anode rod at tracer wire end (Copperhead ANO-1005 or approved equal).
3. Tracer wire shall be 12 gage copper clad steel, extra high strength with minimum 450 lb break load, with minimum 30 mil HDPE insulation thickness.
4. Connections between wires shall be installed with 3-way lockable connectors with dielectric silicon fill to seal out moisture and corrosion.



STANDARD DETAILS
SANITARY SEWER SERVICE RISER

FARMINGTON, MINNESOTA

Last Revision:
FEB 2017

City Plate No.
SER-02
2017